

Annual Drinking Water Quality Report
For the Town of Warrenton
PWSID # 0112600

INTRODUCTION

This Annual Drinking Water Quality Report for calendar year 2001 is designed to inform you about your drinking water quality. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand the efforts taken by the Town of Warrenton to protect your water supply. The quality of your drinking water must meet state and federal requirements administered by the Virginia Department of Health (VDH).

If you have questions about this report, or if you want additional information about any aspect of your drinking water or want to know how to participate in decisions that may affect the quality of your drinking water, please contact:

Edward B. Tucker, Director of Public Works/Utilities, at 347-1858
or
William Stoddard, Superintendent Water/Wastewater, at 347-1104

The times and location of regularly scheduled Town Council meetings are the second Tuesday of each month at 7:00 p.m. at Town Hall, 18 Court Street in the Town of Warrenton.

GENERAL INFORMATION

Drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: (1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. (2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. (3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. (4) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. (5) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

SOURCE(S) and TREATMENT OF YOUR DRINKING WATER

The sources of your drinking water are from both surface water and groundwater as described below:

Warrenton Reservoir: Located north of town with a capacity of approximately 120 million gallons.

Airlie Reservoir: Located northwest of town on the Airlie Foundation Property with approximately 183 million gallons for town use.

Well # 5: Located near Rady Park producing approximately 52,000 gallons per day.

Well # 6: Located in the Warrenton Lakes Subdivision producing approximately 20,000 gallons per day.

Your drinking water supply is treated as described below:

The water from the reservoirs is treated by the Water Filtration Plant located at 7240 Blackwell Road, Warrenton, Va. The water from the two wells does not require treatment and is sampled and monitored on a periodic basis to verify its quality.

Under a new program being developed by VDH, a detailed source water assessment will be conducted within the next few years to find ways to better protect our water sources. After the assessment, we will provide information about potential sources of contamination and measures to reduce/eliminate those sources.

DEFINITIONS

Contaminants in your drinking water are routinely monitored according to Federal and State regulations. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2001. In the table and elsewhere in this report you will find many terms and abbreviations that might not be familiar. The following definitions are provided to help you better understand these terms:

Non-detects (ND) - lab analysis indicates that the contaminant is not present

Parts per million (ppm) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity, or cloudiness, of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is monitored because it is a good indicator of the effectiveness of our filtration system.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level, or MCL - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level, or SMCL - Maximum contaminant levels may be either "primary" (PMCL), meaning based on health considerations or "secondary" (SCML) meaning based on aesthetic considerations.

Maximum Contaminant Level Goal, or MCLG - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

WATER QUALITY RESULTS

I. Microbiological Contaminants – Were there any detections? () Yes, as described below. (X) No

Contaminant	MCLG	MCL	No. of Samples Indicating Presence of Bacteria	Violation (Y/N)	Sampling Year	Typical Source of Contamination
Total coliform bacteria	0	1 positive monthly sample	None	No	2001	Naturally present in the environment.
Fecal coliform bacteria	0	A routine sample and a repeat sample are total coliform positive, and one is also fecal positive.	None	No	2001	Human and animal fecal waste.

II. Lead and Copper Contaminants – Were there any detections? () Yes, as described below. () No

Contaminant	Units of Measurement	Action level	MCLG	Results of samples for the 90 th Percentile Value	Action Level Exceedance (Y/N)	Sampling Year	# of Sampling Sites Exceeding Action level	Typical Source of Contamination
Lead	ppb	15	0	ND	N	8/2000	0	Corrosion of household plumbing systems.
Copper	ppm	1.3	1.3	0.285 ppm	N	8/2000	0	Corrosion of household plumbing systems.

III. Turbidity – Were there any detections? () Yes, as described below () No.

Contaminant	Treatment Technique Limits	Level detected	Violation (Y/N)	Sampling Year	Typical Source of Contamination
Turbidity	5 NTU maximum ≤0.5 NTU 95% of the time	highest single measurement = .28 ntu lowest monthly percentage = 100%	No No	2001 2001	Soil runoff

IV. Other Chemical and Radiological Contaminants – Were there any detections? () Yes, as described below. () No

Contaminant	Units of Measurement	MCLG	MCL	Level Detected	Violation (Y/N)	Range of Detection at Sampling Points	Sampling Year	Typical Source of Contamination
Alpha Emitters	pCi/L	0	15	3.7	N	0.1-3.7	2000	Erosion of natural deposits in the earth. ¹
Nitrate	ppm	10	10	2.84	N	0.10 – 2.84	2001	Erosion of natural deposits in the earth. ²
Fluoride	ppm	4	4	0.69	N	0.69-1.35	2001	Erosion of natural deposits; water additive Which promotes strong teeth; discharge from Fertilizer and aluminum factories

¹ Some people who drink water containing alpha emitters and radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer

² Nitrate levels may rise quickly for short periods of time because of rainfall and can be due to runoff from fertilizer use; leakage from septic tanks; sewage; and erosion of natural deposits in the earth

The Town constantly monitors for various contaminants in the water supply to meet all regulatory requirements. The tables list only those contaminants that had some level of detection. Many other contaminants have been analyzed but were not present or were below the detection limits of the lab equipment.

Several of the results in the table are from testing conducted in 2000. However, the state allows the Town to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though accurate, is more than one year old.

Are there other drinking water constituents we want to inform you about in this report? (X) Yes, as described below. () No

1. Manganese was detected and measured at 0.064 ppm. The SMCL is 0.05ppm. The source of the manganese comes from the deeper water levels drawn from the reservoir. Twice a year the Reservoir turns over (a naturally occurring phenomena for lakes) which raises the manganese levels for 2 to 3 weeks until the reservoir stabilizes and the manganese returns to below the SMCL.
2. We are pleased to report that MTBE (Methyl Tertiary Butyl Ether - a gasoline additive) has been tested for and found to be non-detectable

The U.S. Environmental Protection Agency sets MCL's at very stringent levels. In developing the standards EPA assumes that the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCLs at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-a-million chance of having the described health effect for other contaminants.

VIOLATION INFORMATION: Your water system did not have any violations during 2001.

The staff of the Town of Warrenton takes its responsibilities to the citizens of the community who are serviced by the water system very seriously. To ensure the safe and efficient operation of the Town's municipal water supply system and provide a healthy, safe and aesthetically pleasing water to our customers is a service we are proud to perform. Should you have any questions, want additional information, or feel that a particular health effect has not been addressed, please contact Edward B. Tucker, Director of Public Works/Utilities at 347-1858 or William Stoddard, Water/Wastewater Superintendent, at 347-1104.

This Drinking Water Quality Report was prepared by:

Edward B. Tucker, Jr.
Director of Public Works/Utilities